



Product Service

CERTIFICATE

No. Z1A 13 11 76175 004

Holder of Certificate: **ESPA 2025, SL**
 Ctra. Mieres s/n
 17820 Banyoles (Girona)
 SPAIN

Factory(ies): 76175

Certification Mark:



Product: **Circular Pumps
 Circulating Pumps**

Model(s): **Silen 30M, Silen 50M, Silen 75M, Silen 100M,
 Silen 150M, Silen 30, Silen 50,
 Silen 75, Silen 100, Silen 150**

Parameters:	Silen 30M, Silen 50M, Silen 75M, Silen 100M Silen 150M	Silen 30, Silen 50 Silen 75, Silen 100 Silen 150
Rated voltage:	230V AC 50Hz	400V 3AC 50Hz
Rated power:	700W, 800W 1200W, 1400W, 1600W	800W, 900W 1300W, 1500W, 1600W
Protection class:	I	I
Protection degree:	IP55	IP55
Medium temperature:	35°C	35°C
Throughput capacity:	(100-425) l/min.	(100-425) l/min.
Minimum height:	3,0m – 5,0m	3,0m – 5,0m
Maximum height:	11,5m – 18,5m	11,5m – 18,5m

Tested according to: EN 60335-2-41/A2:2010
 ZEK 01.4-08

The product meets the safety and health requirements of the German Product Safety Act section 20 to 22 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. See also notes overleaf.

Test report no.: 713027028-04

Valid until: 2018-11-21

Date, 2013-11-22


 (Werner Müller-Starke)





Product Service

ZERTIFIKAT

Nr. Z1A 13 11 76175 004

Zertifikatsinhaber: **ESPA 2025, SL**
 Ctra. Mieres s/n
 17820 Banyoles (Girona)
 SPANIEN
 76175

**Produktions-
 stätte(n):**

Prüfzeichen:



Produkt: **Kreiselpumpen
 Umwälzpumpen**

Modell(e): **Silen 30M, Silen 50M, Silen 75M, Silen 100M,
 Silen 150M, Silen 30, Silen 50,
 Silen 75, Silen 100, Silen 150**

Kenndaten:	Silen 30M, Silen 50M, Silen 75M, Silen 100M Silen 150M	Silen 30, Silen 50 Silen 75, Silen 100 Silen 150
Nennspannung:	230V AC 50Hz	400V 3AC 50Hz
Nennaufnahme:	700W, 800W 1200W, 1400W, 1600W	800W, 900W 1300W, 1500W, 1600W
Schutzklasse:	I	I
Schutzart:	IP55	IP55
Medium		
Temperatur:	35°C	35°C
Durchsatz/Qmax:	(100-425) l/min.	(100-425) l/min.
Mindesthöhe:	3,0m – 5,0m	3,0m – 5,0m
Maximalhöhe:	11,5m – 18,5m	11,5m – 18,5m

Geprüft nach: EN 60335-2-41/A2:2010
 ZEK 01.4-08

Das Produkt entspricht hinsichtlich der Gewährleistung von Sicherheit und Gesundheit den Anforderungen des deutschen Produktsicherheitsgesetzes § 20 bis 22 ProdSG. Es kann mit den oben abgebildeten Prüfzeichen gekennzeichnet werden. Eine Veränderung der Darstellung der Prüfzeichen ist nicht erlaubt. Die Übertragung eines Zertifikates durch den Zertifikatsinhaber an Dritte ist unzulässig. Das Zertifikat ist gültig bis zum angegebenen Zeitpunkt, sofern es nicht früher gekündigt wird. Umseitige Hinweise sind zu beachten.

Prüfbericht Nr.: 713027028-04
Gültig bis: 2018-11-21

Datum, 2013-11-22

(Werner Müller-Starke)

Seite 1 von 1

